

**SYNTHESIS DOCUMENT**  
**PRODUCTS CONFORMITY ASSESSMENT**  
**ERIFLEX BRAIDS IBS, IBSB, IBSBR**  
**TOTAL INSULATION (CLASS II)**  
THIS DOCUMENT CANCELS AND REPLACES THE PRECEDENT ON 03/28/2014

### 1 SCOPE OF THIS DOCUMENT

The present document constitutes the synthesis of the APAVE report n° 7472740-001-1 which gives the details of inspections and tests achieved on the product.

### 2 CONCERNED PRODUCT    SPECIFIED FEATURE

- |                 |                        |                                |                                 |
|-----------------|------------------------|--------------------------------|---------------------------------|
| • Name :        | ISOLATED BRAIDED SHUNT |                                |                                 |
| • Designation : | /                      | • Rated voltage :              | 1000 V                          |
| • Make :        | ERIFLEX                | • Neutral position (class II): | TN and TT - 830 V<br>IT - 600 V |
| • Model :       | IBS, IBSB, IBSBR       | • Serial number :              | /                               |

### 3 SCOPE OF THE MISSION (to see details in report )

Conformity Assessment of the product and its technical file to the following documents :

⇒ NF EN 61439-1 (2012) / IEC 61439-1 (2011) § 8.4.4

### CONCLUSION OF THE REPORT

The conclusion of the report shows that the examined product is in compliance with the prescriptions of the reference documents.

**Tassin the 12/20/2012**

**The Manager of the test laboratory**

Document original immatériel



**Xavier SCHMITT**

**Limit of validity of this document : 5 years**